



2.04 Motors and Drives:

1. Motors shall be mounted to be accessible and removable through the casing access door. All motors shall be manufactured to be high efficiency and designed to be used with variable frequency drives.
2. ABB