

Laboratory Safety Inspection Form		
-----------------------------------	--	--

Building:	Room(s):	Department:
-----------	----------	-------------

Date of Inspection:	Laboratory Manager:	Inspected by:
---------------------	---------------------	---------------

Yes	No	N/A	
-----	----	-----	--

<b>Laboratory Access/ Emergency</b>			
-------------------------------------	--	--	--

			Laboratory controlled access (doors locked when unoccupied).
--	--	--	--

			Emergency contact information is posted in the laboratory.
--	--	--	--

<b>Electrical Safety (NFPA)</b>
---------------------------------

Electrical cords/outlets/plugs are in good working condition.

Use of extension cords is noted throughout the laboratory. Extension cords should not be used as a substitute for permanent wiring and no extension cords should be used in the laboratory.

Laboratory Safety Inspection Form		
Building:	Room(s):	Department:
Date of Inspection:		

Laboratory Safety Inspection Form

Building:	Room(s):	Department:
Date of Inspection:	Laboratory Manager:	Inspected by:

***Chemical Safety***

			Hazardous chemical containers stored safely and within reach.
			Flammable chemicals are not stored in a household refrigerator.
			Chemicals are stored safely to prevent creating a tripping hazard.
			Chemicals are appropriately segregated based on hazard classification.
			Chemical containers are kept in good working condition.

Perchloric