

4.01.03 – CAMPUS CONDITIONS
DESIGN AND CONSTRUCTION STANDARDS

CAMPUS CONDITIONS

Campus “design” conditions will vary between Sam Houston State University campuses; however, the following list of conditions is provided for the Main Campus. Even within the Main Campus, the following are considered typical design conditions and will vary based specific project location and utility availability. The designer should establish actual conditions with the University at the beginning of each project including potential utility tie-in locations and requirements.

Hot Water Supply Temperature:

Indoor design conditions:

Winter = 68°F +/- 2°F

Summer = 75°F +/- 2°F

Relative Humidity = 50% +10% / -20%

Note: Specialized spaces, such as IT rooms, may be subject to different design conditions. Coordinate with project requirements.